

# Review Data | SDWARS

PWS ID	Facility	Sample Point	Sampling Event	Lab	Sample ID	Collection Date	Method	Analyte	Result Measure µg/L	Status
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	200.7	lithium	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	11Cl-PF3OUdS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	4:2 FTS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	6:2 FTS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	8:2 FTS	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	9CI-PF3ONS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	ADONA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	HFPO-DA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	NFDHA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFBA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFBS	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFDA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFDoA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFEESA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFHpA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFHpS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFHxA	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFHxS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFMBA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFMPA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFNA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFOA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFOS	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFPeA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFPeS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	533	PFUnA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	537.1	NEtFOSAA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	537.1	NMeFOSAA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	537.1	PFTA	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE2	Northern Lake Service, Inc.	105718P	7/12/23	537.1	PFTTrDA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	200.7	lithium	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	11Cl-PF3OUdS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	4:2 FTS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	6:2 FTS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	8:2 FTS	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	9CI-PF3ONS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	ADONA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	HFPO-DA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	NFDHA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFBA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFBS	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFDA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFDoA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFEESA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFHpA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFHpS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFHxA	< MRL	PWS/EPA Approved



<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFHxS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFMBA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFMPA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFNA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFOA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFOS	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFPeA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFPeS	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	533	PFUnA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	537.1	NEtFOSAA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	537.1	NMeFOSAA	< MRL	PWS/EPA Approved
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	537.1	PFTA	< MRL	PWS/EPA Approved

<b>PWS ID</b>	<b>Facility</b>	<b>Sample Point</b>	<b>Sampling Event</b>	<b>Lab</b>	<b>Sample ID</b>	<b>Collection Date</b>	<b>Method</b>	<b>Analyte</b>	<b>Result Measure µg/L</b>	<b>Status</b>
IL1130750	TP02	TP02	SE1	Northern Lake Service, Inc.	100218P	1/18/23	537.1	PFTTrDA	< MRL	PWS/EPA Approved